

SCOPE OF WORK

Fire Sprinkler Systems
Hard Rock Hotel and Casino Parking Garage
777 W Cherokee St
Catoosa, OK 74015

Engage **VENDOR** to supply all labor and materials to perform annual inspection of the dry pipe sprinkler system located in the parking garage at the Hard Rock. This inspection will be in accordance with **OAC 310:205-3-7, NFPA #13** and the **Local Authority having Jurisdiction**. **VENDOR** will use only approved methods and materials to complete this work. All work will be performed during approved normal business hours.

VENDOR will perform the work indicated below:

- 1 inspection of a single dry pipe system including all valves, drains, connections
- 1 inspection of cabinets and all other devices related to parking garage dry pipe system