

## SCOPE OF WORK

---

Fire Sprinkler Systems  
Hard Rock Hotel and Casino  
777 W Cherokee St  
Catoosa, OK 74015

Engage **VENDOR** to supply all labor and materials to perform annual inspection of the fire sprinkler systems located at the facility. This inspection will be in accordance with **OAC 310:205-3-7, NFPA #13** and the **Local Authority having Jurisdiction**. **VENDOR** will use only approved methods and materials to complete this work. All work will be performed during approved normal business hours.

**VENDOR** will perform the work indicated below:

- 36 wet systems tests and inspections
- 3 double-interlock pre-action systems tests and inspections
- 3 fire pumps inspections to include full flow testing
- 3 fire line Backflow prevention assembly tests and inspections