

**CHEROKEE NATION ENTERTAINMENT: GENERATOR LOG - UPDATED OCTOBER 13, 2016**

Location	Manufacturer	Voltage	Generator Model Number	Generator Serial Number	Size of Genset	Engine Make	Engine Model Number	Engine Serial Number	Fuel Type and Capacity	ATS Manufacturer	ATS Model Number	ATS Serial Number	Notes
Catoosa Casino 1	Caterpillar	480v 3-phase	D3512	SBG00532	1500kW	Caterpillar	3512C	GAW00608	Diesel	Cat	(1) CTG (2) CTG	(1) TSA16627 (2) TSA16179	
Catoosa Casino 2	Caterpillar	480v 3-phase	D3516	FDN01513	2250kW	Caterpillar	3516	LHN00825	Diesel 2100 gal	Asco	Item # 757255	261879 FP	
Catoosa Casino 3	Kohler	480v 3-phase	7m4050	WA-579896-0712	1500kW	Kohler	1500REOZDD	SGM322HJ5	Diesel 3130 gal	Kohler	(1) KCS-DMVA-0400S (2) KCS-DMVA-1200S (3) KCS-DMTA-1600F	(1) SGM32272S (2) SGM32293D (3) SGM322C46	
Catoosa Hotel (Cherokee Tower)	Caterpillar	480v 3-phase	D3412	DJN00194	750kW	Caterpillar	3412	AFK00599	Diesel 660 gal	Asco	Item # 757256	261881 FP	
Ft. Gibson	Kohler	480v 3-phase	2000REOZDD	SGM322792	2000kW	MTU Onsite Energy	16v4000g43	527108691	Diesel 4150 gal	Kohler	KSS-DMVA-0100S	SGM322KG8	
West Siloam	Caterpillar	480v 3-phase	D3508	CNB01075	1000kW	Caterpillar	3508 SR4B	2DN02005	Diesel 900 gal	Kohler	KCS-DMVA-1600S	K2089453	
West Siloam	Caterpillar	480v 3-phase	D3508	CNB00982	1000kW	Caterpillar	3508 SR4B	2DN01909	Diesel 900 gal	(1) Asco (2) Kohler (3) Eaton	(1) G07ATSA31600N5XO (2) KSS-DMTC-0600S (3) FPATS-60D-L1	(1) 260443 (2) SGM326HTT (3) 16BJ570E	
West Siloam Lift Station	Kohler	240V 3-phase	60REOZJB	2145359	62KW	John Deere	4045TF270E	4A07-0573	Deisel	USEMCO	N/A	7100	Transfer test may be performed during regular hours.
West Siloam (Fire Pump)	John Deere	N/A	N/A	N/A	N/A	John Deere	(6.8 L) JU6H-UFG8	PE6068T718081	Diesel	N/A	N/A	N/A	
Roland	Caterpillar	480v 3-phase	D3508	CNB00981	1000kW	Caterpillar	3508	2DN01908	Diesel 900 gal	Asco	(1) H00300030800N10C (2) H00300030800N10C	(1) 254189-003 RE (2) 254189-004 RE	
Roland	Kohler	480v 3-phase	2000REOZMD	SGM32CLB7	2000kW	Mitsubishi	7M4054	SGM32CLB7	Diesel 2200 gal	Kohler	KCP-AMVA-0400S	SGM32CGHP	
Roland Maint Shop	Generac	277/480v 3-phase	99AO6697-5	2051771	60kW	Mitsubishi	85677	N/A	Diesel 308 gal	Asco	D003000030150N10F301	328858-002RE	No transfer test required.
Will Rogers Downs	Kohler	277/480v 3-phase	600REOZM	2062729	600kW	Mitsubishi	S6R-YIPTAA	19558	Diesel 1000 gal	Kohler	ZCS-566341-1200	KO674880	
Ramona	Kohler	480v 3-phase	2000REOZDD	SGM32278X	2000kW	MTU/Detroit	16V4000G43	527108690	Diesel 4150 gal	Kohler	KSS-DMTA-0100S	K2321813	
Sallisaw	Kohler	480v 3-phase	200REOZJF	SGM3296CK	200kW	John Deere	R504850JD6068	EE6068L934794	Diesel 400 gal	Kohler	KSS-DMVC-0400S	SGM328WTG	
Tahlequah Casino	MTU Onsite Energy	480v 3-phase	433CSL6220-2	705551 03-10	400kW	MTU Onsite Energy	400 PX 56 DT 3	318951-1-1-0310	Diesel 850 gal	Lakeshore	101-0177	1CFA31600PBSF	
Tahlequah Casino	Katolight	208v 3-phase	D50FPJ4	LM-351329-61446	50kW	John Deere	4045TF150	PE4045T103163	Diesel 130 gal	Asco	D003000030200G10F	488988	No maintenance required. Not included in contract.
Tahlequah Corporate Office	Kohler	120/240 Single phase	45RZG	711512	40kW	GM	GM 4.3	4.3L-13353	Natural Gas	Asco	A300220061XC	4.3L13353	
Tahlequah Mobile Generator	Generac	120/220v Single phase	20A02488-S	2057655	35kW	Generac ???	C2920	3.0LHA	Diesel 55 gal	None	None	None	No transfer test required.
Tahlequah 4th St.	Kohler	120/240v Single phase	60REOZJB	2193911	60kW	John Deere	4045TF270	PE4045T668174	Diesel	Kohler	KSS-DFTC-02255	K2192616	
Grove	Kohler	480v 3-phase	2000REOZMD		2000kw	Mitsubishi	S16R-Y2PTAW2-1		Diesel 4150 gal	Kohler	KCP-AMVA-0150S		
S. Coffeyville-Casino	Kohler	277/480v 3-Phase	600REOZVB	SGM32C8FD	600kW	Volvo	TWD1643GE	D16*082371*C3*A	Diesel 1033 gal	Kohler	KEP-DMVC-08005-RQ	SGM32C9KD	
S. Coffeyville-Lift Station	Generac	277/480v 3-phase	QT04524KNSX	9284680	45kW	Mitsubishi	EGNXB02	T8150	Natural Gas	EATON	KPG27511	ATC3C2X30100XRU	Transfer test may be performed during regular hours.