

10 November 2010

Addendum A to the Bidding Documents for:

CNE – Interchange Park Tenant Improvement
10838 East Marshall Street
Tulsa, Oklahoma 74116

Project Number R10053

Drawings

Issue 01; dated 05 November 2010

The contents of this Addendum A supersede and supplement all portions of the above referenced bidding documents (*including project manual and **all** associated drawing sets*) with which Addendum A conflicts.

DRAWINGS

CS – COVER SHEET

Item 1 Revise sheet index

A5/A001 – ROOM SCHEDULE

Item 1 Add “PLAM2 Wilsonart 1851K-35 Luna Glow” to the Material/Color Legend.

A3/A102 – FLOOR PLAN

Item 1 Add dimension string to transaction counter.

A1/A120 – REFLECTED CEILING PLAN

Item 1 Add 2 x 4 lay-in ceiling grid.

Item 2 Add light fixtures to Conference Room 1044.

Item 3 Add suspended direct/indirect fluorescent light fixture to symbol legend.

E1/A120 – CHECK-IN COUNTER

Item 1 Add new detail in its entirety.

A1/M103 – HVAC FLOOR PLAN

Item 1 Ductwork and diffuser locations shifted to coordinate with lights.

A1 /E201 – EAST LIGHTING PLAN

Item 1 Add emergency light fixtures in various areas.

Item 2 Suspended light fixture in Secure Storage 1018 shifted to coordinate with ductwork.

E3 /E201 – KEYNOTES

Item 1 Add key note 26.103.

Item 2 Add key note 26.104.

A3 /E201 – CENTER LIGHTING PLAN

Item 1 Add fixture type A1 in the Conference Room 1044.

Item 2 Replace fixture type A to type A1 in the War Room 1043.

Item 3 Add emergency light fixtures in various areas.

Item 4 Label the suspended fixture B1 for 8 footer.

Item 5 Suspended light fixture in Workspace 1038 shifted to coordinate with ductwork.

A1/E202 – West Lighting Plan

Item 1 Add emergency light, exist sign and emergency / exist combo fixtures in various areas.
Item 2 Reroute light fixture and switching to other branch circuits in Workspace 1072.
Item 3 Label the suspended fixture B1 for 8 footer and B2 for 4 footer
Item 4 Suspended light fixture in Workspace 1059 and 1086 shifted to coordinate with ductwork.

E3 /E202 – KEYNOTES

Item 1 Add key note 26.104

A1/E501 – PANEL BOARD SCHEDULES

Item 1 Panel D - Revise branch circuit D-24, D-26 to spare.
Item 2 Panel P - Revise branch circuit P-39, D-41 to workspace lighting.

A1/E502 – PANEL BOARD SCHEDULES

Item 1 Revise lighting fixture schedule.
Item 2 Revise the RTU5, RTU22, RTU27 circuit breaker sizes.
Item 3 Add lighting contactors details

ATTACHMENTS:

COVER SHEET

A001 FRAME AND PARTITION TYPES, AND SCHEDULES
A102 FLOOR PLAN AND ENLARGED FLOOR PLANS
A120 REFLECTED CEILING PLAN AND DETAILS
M103 ENLARGED HVAC PLANS
E201 ENLARGED LIGHTING PLAN
E202 ENLARGED LIGHTING PLAN
E501 PANEL BOARD SCHEDULES
E502 PANEL BOARD SCHEDULES

END OF ADDENDUM 1