

Questions and Answers 02.05.2024

RFP 151816

Purchase and Installation of Cameras

Russellville, AR

1. Section #3 of Procurement #151816 states that the Vendor is to provide five category 5 network drops for the requested cameras. Please advise if category 6 cable will suffice for this project.

A minimum of Category 5 is needed, but Category 6 cable will work as well.

2. Will a surveillance server need to be provided by the Vendor?

A surveillance server will not be required from the vendor.