

ADDENDUM #01

RFB – RSHC GENERATOR PROJECT

06/26/2025

**SEALED BIDS MUST BE RECEIVED ON OR BEFORE THURSDAY JULY 2, 2025 BY 3:00 P.M. CT TO BE
CONSIDERED.**

QUESTIONS SUBMITTED FROM INTERESTED PARTIES:

1. Due to the concern on clearances, mounting such a large ATS indoors, the question was brought up on the walk through. Can an outdoor ATS be quoted for the project, and mount it where the existing disconnect is currently located? The ATS is service entrance rated, so it has a breaker that is a disconnect.

Yes, an outdoor ATS would be acceptable.