

HOUSING REHAB SITE DIRECTIONS


Name: Chandra Willis

Telephone: (918)406-4826

Address: 2727 N. Boston Pl
Tulsa, OK 74106

GPS Coordinates: 36.19435,-95.99492

Drive Time: 1.5 hrs



Directions: From Cherokee Nation, Take Hwy 82 north to Locust Grove, turn left on Cherokee Turnpike to Tulsa. On Hwy 412 in Tulsa turn right on Hwy 11 toward Airport. Go 6.5 miles take exit Mohawk Blvd, turn left to Peoria. On Peoria go south under overpass an turn right on Mohawk Ave. Go 1 mile to MLK Blvd turn right, go north turn left on E 27th St . Go to N Boston PL an turn right. 5th house on the right

C. Gann
Inspector

7/24/2025
Date

WorkWrite-Up and Bid Document/By Trade

Chandra Willis (Emerg Roof)

2727 N. Boston Pl Tulsa, OK 74016

(918) 406-4826

Contractor Name:

Contractor Signature:

This document must be signed to be a valid bid.

PROJECT TYPE: Emergency Repairs

Bid Due Date:

Trade	Work Description / Comments	Gen. Spec.	Qty Unit	Item Bid
Carpentry				
1 Area: EXTERIOR	Fascia/Cover with Metal-Aluminum min .027 thick Heavy Duty Aluminum with baked on finish. Pop rivet all corners and joints. Rolled stiffener bead . Install over front porch, homeowner may have the metal fascia.	Div.# 15.C.	18 LF	
2 Area: EXTERIOR	Fascia/Replace/1" x 4". Replace Fascia/1" x 4". Replace over the front porch, make all repairs needed for installation.	Div.# 6.P	18 LF	
3 Area: EXTERIOR	Install Trim Install trim 2x2 trim Install trim (Shingle Mold) over front porch.	Div.# 6.P	18 LF	
4 Area: EXTERIOR	Soffit/Cover with Vinyl/Cover soffit with vinyl (perforated). Install over the front porch, several pieces have came off, can ask homeowner if they have the vinyl soffit pieces.	Div.# 15.C.	21 SF	
Roofing				

Print Date: Thursday, July 24, 2025

2727 N. Boston Pl Tulsa, OK 74016

Page 1 of 2

Trade	Work Description / Comments	Gen. Spec.	Qty Unit	Item Bid
Roofing				
5	Area: ROOF Replace Shingles / Install Heritage/30 Yr Warranty, Fiberglass shingles/Use Marlarky/Tamko or approved equal. 30 lb Felt, Painted Style D Drip Edge, Pipe Flashing, Valley Flashing, Step Flashing & Slant Back Attic vents.	Div.# 7.A.	19 Sq	
6	Area: ROOF Roofing/Strip/Asphalt-Fiberglass 1 Layers. Strip roof--asphalt/fiberglass/1 layers.	Div.# 7.C	17 Sq	
7	Area: ROOF Sheathing/Replace/Match Existing. Replace existing sheathing. Match existing as closely as possible. Replace decking where needed.	Div.# 7.B	128 SF	

All construction shall be in accordance with local codes, manufacturers' recommended installation procedures, good quality workmanship practices, General Specifications and Lead-Based Paint requirements when applicable. Conflicts between requirements will be resolved by compliance with the more stringent requirement.

Total: