

HACN HOUSING REHAB SITE DIRECTIONS


Name: Phillip Adams

Telephone: (918)944-9300

Address: Po box 1701
locust Grove, OK 74352

County: Mayes **Year Built:** 1970

GPS Coordinates: 36.1985375-95.190721 **Drive Time:** 1hr



Directions: From Cherokee Nation, turn left go 2mi turn right go 2mi to 62/82 jct continue north on hwy 82 go to lucust grove once arrive at stoplight turn left go west thru town on hwy 412 to cr S439 turn right go 1/2mi house be on left

Melvin Blossom
Cost Estimator/Inspector

8/1//2025
Date

WorkWrite-Up and Bid Document/By Trade

Phillip Adams

PO Box 1701 Locust Grove, OK 7-4352

(918) 944-9300

Contractor Name:

Contractor Signature:

This document must be signed to be a valid bid.

PROJECT TYPE: Emergency Repairs Bid Due Date:

Trade	Work Description / Comments	Gen. Spec.	Qty Unit	Item Bid
HVAC				
1 Area: HVAC		Div.# 12.M.	400 LF	
Ductwork/Repair Ductwork/Clean. Repair/Clean Ductwork				
2 Area: HVAC		Div.# 12	1 Ea	
HVAC Equipment Replace/ Replace existing with 3.0 Ton 16 seer ELECTRIC HEAT & COOLING. COMPLETE CHANGE OUT /INCLUDING: PLENUM, FILTER GRILL, REGISTERS, THERMOSTAT, ALL WIRING & CONDENSOR LINES. CHECK; Duct Work for Leaks & make all necessary repairs.				

All construction shall be in accordance with local codes, manufacturers' recommended installation procedures, good quality workmanship practices, General Specifications and Lead-Based Paint requirements when applicable. Conflicts between requirements will be resolved by compliance with the more stringent requirement.

Total: