



HACN HOUSING REHAB SITE DIRECTIONS

Unit # 14310

Telephone: (918)353-3950

Address: 22095 Hwy 20

Jay, OK 74346

County: Delaware **Year Built:** 1970

GPS Coordinates: 36.43355 / -94.64462 **Drive Time:** 1.5 hrs

Directions: From Cherokee Nation,
Take Hwy 62 east 7 miles to Hwy 10
Take hwy 10 north 44 miles to Hwy 20 east - Jay
Take Hwy 20 east 8.8 miles
Driveway on right

David Tackett [918] 822-2985

11-6-25

Cost Estimator/Inspector

Date

Unit # 14310 WorkWrite-Up and Bid Document/By Trade

Electrical

22095 Hwy 20 Jay, OK 7-4346
(918) 353-3950

Contractor Name:

Contractor Signature:

This document must be signed to be a valid bid.

PROJECT TYPE: Emergency Repairs Bid Due Date:

Trade	Work Description / Comments	Gen. Spec.	Qty Unit	Item Bid
Electrical				
1 Area: ELECTRICAL		Div.# 13.D. 1	1 Ea	
Main Service/150 Amp/Install. Install new main Service with new 150 AMP service with 18 branch breakers. . According to NEC				
2 Area: ELECTRICAL		Div.# 13.D.	35 Ea	
Outlet/110v Single Receptacle & Circuit/20 Amp/Grounded/Install new. Install new 110v single receptacle outlet and cover plate. entire interior				
3 Area: ELECTRICAL		Div.# 13.D. 4	4 Ea	
Outlet/GFCI/Replace GFCI wall outlet/See comments. bath and kitchen				
4 Area: ELECTRICAL		Div.# 13.D.	20 Ea	
Switch & Cover Plate/20 Amp/Replace switch and cover/20 amp. entire interior				

Trade	Work Description / Comments	Gen. Spec.	Qty Unit	Item Bid
All construction shall be in accordance with local codes, manufacturers' recommended installation procedures, good quality workmanship practices, General Specifications and Lead-Based Paint requirements when applicable. Conflicts between requirements will be resolved by compliance with the more stringent requirement.				
Total:				