

ADDENDUM #02

RFP 164640 – CNHS MEDICAL GAS SERVICES

06/26/2026

BIDS MUST BE RECEIVED ON OR BEFORE JULY 01, 2026 BY 5:00 P.M. TO BE CONSIDERED.

1. Please clarify whether the expectation is for us to procure all PM parts for the full five-year term upfront, or if PM parts will be ordered annually as each year's preventative maintenance is performed.

Order parts each year.

- How would inflation costs be handled based on the above response?

Use a separate line for parts and inspection.

- How would Cherokee Nation handle parts that become obsolete once systems are replaced?

Keep parts that can be used on other sites or dispose of obsolete parts.

2. Please confirm whether Category 3 dental clinics are included in the requirement for 100% testing.

All testing to be completed based on the applicable codes based on building age.

- We would base our pricing on a per trip basis due to not knowing how many trips may be needed.

Please see the attached sheets for the zone valve boxes and outlet counts per location.

Sam Hider Health Dental

Total Alarm Count	2
Total Outlet Count	16
Total Valve Count	2

Redbird Smith Health Center Dental

Total Outlet Count	4
Total Valve Count	3
Total Alarm Count	1

Replacement Hospital

Total Alarm Count	33
Total Outlet Count	1735
Total Valve Count	179

Vinita Health Center Dental

Total Alarm Count	2
Total Outlet Count	32
Total Valve Count	3

Cooweescoowee Health Center Dental

Total Outlet Count	16
Total Valve Count	2
Total Alarm Count	2

Will Rogers Health Center

Total Alarm Count	2
Total Outlet Count	16
Total Valve Count	2

Three Rivers Health Center Dental

Total Alarm Count	2
Total Outlet Count	18
Total Valve Count	3

AMO Health Center Dental

Total Outlet Count	16
Total Valve Count	2

WPM Health Center Dental

Total Count	32
-------------	----

W.W. Hastings Hospital

Total Alarm Count	54
Total Outlet Count	753
Total Valve Count	92

CNOHC

Total Alarm Count	40
Total Outlet Count	519
Total Valve Count	90