



CONSTRUCTION DOCUMENTS – ADDENDUM 04

Date: September 20, 2019

Re: Oklahoma State University
College of Osteopathic Medicine
at Cherokee Nation

From: James R Childers Architect, Inc.
45 South 4th Street
Fort Smith, Arkansas 72901



09-20-19

This addendum forms part of the Contract Documents, and modifies the documents as noted below. Acknowledge receipt of this addendum in the space provided on the bid form. Failure to do so may subject the bidder to disqualification.

- Item 01** Please refer to revised drawings
- Item 02** Please refer to revised specifications
- Item 03** Please refer supplemental information for Radon Mitigation Design
- Item 04** Please refer to attached narrative

CONSTRUCTION DOCUMENTS – ADDENDUM 004 – 09-20-2019

ARCHITECTURAL DRAWINGS

AS.01

Detail 04 – Finish notes were added for railing

A1.32B

Door 3014 relocated to the south wall.

A3.01

01/East Elevation – Dimensions & specifications for exterior signage have been added.

A6.00

The following door hardware has been revised

Basement Level – B001, B003C, B006, B007A, B010B, B014A, B016

Level 1 – 1009A, 1009B, 1009C, 1010, 1011A, 1011B, 1012, 1015, 1017, 1024, 1025, 1026A, 1026B, 1027, 1032, 1037A, 1037B, 1040, 1046, 1047, 1055, 1056A, 1056B, 1059, 1060A, 1060B, 1064, 1066, 1067

Level 2 – 2010, 2016, 2045, 2046A, 2046B, 2047A, 2047B, 2048A, 2048B, 2049A, 2049B, 2050A, 2050B, 2051A, 2051B, 2053, 2055A, 2055B, 2056A, 2056B, 2058A, 2058B, 2059A, 2060A, 2061A, 2061B, 2066A, 2066B, 2067A, 2067B, 2073A, 2078

Level 3 – 3000, 3001, 3006A, 3006B, 3006C, 3007, 3015, 3017, 3020, 3021, 3022, 3027, 3032, 3037, 3039, 3049, 3050, 3051, 3091A, 3091B, 3106A, 3106B, 3108, 3110A, 3110B

A8.00

Interior Finish Legend – TR-1 – Finish/Product Color has been revised.

Interior Finish Legend – TR-2 – Product & Finish/Product Color has been revised.

Interior Finish Legend – RF-1 – Finish/Product has been revised.

Interior Finish Legend – RF-2 – Finish/Product has been revised.

Interior Finish Legend – SB – Finish/Product has been revised to coordinate w/ RF-1 & RF-2 revisions.

Interior Finish Schedule – WC-3 denotation has been removed from Corridor 1029.

Interior Finish Schedule – MB denotation has been added.
Interior Finish Schedule – TZB denotation has been removed from 1003, 1004, 1029, 2000, 2001.

A8.32

Electrical Storage 3014 – Transition location revised due to door relocation.

MECHANICAL DRAWINGS

M1.02 – MULTI-ZONE VAV ROOF TOP UNIT WITH GAS FIRED HEAT SCHEDULE

Revised note #8.

M2.16

Added Radon Mitigation fan locations to plan.

Added keynote 23.41.

ELECTRICAL DRAWINGS

E1.16

Relocated receptacles in L3 Elec S 3014.

Revised floor box in Faculty Conf 3 3027 to FB1.

E1.17

Relocated receptacles in L3 Elec S 3014.

E1.36

Relocated power connections for radon exhaust fans.

E2.01

Added light fixtures B1E, E1 and S1E to light fixture schedule.

E2.02

Added light fixture E1 in room B019.

Added light fixture E1 in room B018.

Added light fixture E1 in room B028.

Added light fixture E1 in room B002.

Changed light fixtures in BSMT Stairs S to S1E

E2.04

Added light fixture E1 in OMM AV room.

Added light fixture E1 in L1 Elec N 1063

Changed light fixtures in L1 Stair N to S1E.

E2.05

Added light fixture E1 in Sim Serv 1039

E2.06

Added light fixture E1 in LH 1 AV room.

Added light fixture E1 in L1 IDF 1008.

E2.07

Added light fixture E1 in L1 Elec S 1016.

Changed light fixtures in L1 Stair S to S1E.

E2.09

Changed light fixtures in L2 Stair N to S1E.

Added light fixture E1 to CS AV room.

Added light fixture E1 to L2 Elec N.

E2.10

Added light fixture E1 to CE Server 2054.

E2.11

Added light fixture E1 to L2 IDF 2005.

E2.12

Added light fixture to L2 Elec S 2014.

Changed light fixture in L2 Stair S to S1E.

E2.14

Changed light fixtures in L3 Stair N to B1E.

E2.15

Added light fixture E1 to L3 Elec N 3101.

E2.16

Added light fixture E1 to LH 2 AV room.

Added light fixture E1 to L3 IDF 3005.

E2.17

Added light fixture E1 to L3 Elec S 3014.

Changed light fixtures in L3 Stair 3 to B1E and S1E.

PLUMBING DRAWINGS

P2.11, P2.12, P2.21, P2.22, P2.31, P2.32

A cloud has been added to these sheets indicating the area's that are required to have the Holdrite system per note 22.41.

The following information has been added to note 22.41, "on sanitary, vent, CW and HW piping."

P3.11, P3.12, P3.21, P3.22, P3.31, P3.32

A cloud has been added to these sheets indicating the area's that are required to have the Holdrite system per note 22.41.

Note 22.14 has been added to the area's that are required to have the Holdrite system.

Note 22.14 has been added to the keyed notes.

The following information has been added to note 22.41, "on sanitary, vent, CW and HW piping."

EQUIPMENT DRAWINGS

EQ1.32

Furniture moved south to accommodate relocated door.

SPECIFICATIONS

1. FOLLOWING SECTION WAS DELETED FROM CONSTRUCTION DOCUMENT:
 - a. 01 8111 Sustainable Construction Requirements.
2. Section 08 7100, Door Hardware: Revisions to hardware sets, identified in gray highlight.
3. Section 09 3000 Tiling: deleted paragraph 209,H, "Epoxy Grout" .
4. Section 09 6566, Resilient Athletic Flooring: Deleted paragraph 3.5, "Game Lines and Markers".