



# 1 PORTE COCHERE TOP VIEW - LIGHTING CALCULATION

1" = 20'-0"

# 2 1ST FLOOR RCP - LIGHTING

3/64" = 1'-0"

LIGHTING CALCULATION - PORTE COCHERE

Calculation Points Name	Average	Maximum	Minimum	Average / Minimum	Maximum / Minimum
<b>PORTE COCHERE</b>	<b>30 fc</b>	<b>49 fc</b>	<b>0 fc</b>	<b>63.2</b>	<b>102.2</b>

TYPE	DESCRIPTION	MFGR. & CATALOG No.	LAMP	DRIVER VOLTAGE	UNIT WATTS	COLOR TEMP [K]
D02A	6" APERTURE HI LUMEN LED REMODEL EXTERIOR DOWNLIGHT. DAMP LOCATION RATED.	PATHWAY: RMD6LBV 70-4K-XX-XW60-SCLPF OR APPROVED EQUAL.	90 CRI 7000 LUMEN LED	120/277V	75W	4000K

## ADDENDUM 02

**ME ENGINEERING**  
 Mechanical/Electrical Engineering Consultants  
 Buffalo | Rochester | Syracuse | Schenectady  
 60 LAKEFRONT BLVD., SUITE 320 BUFFALO, NY 14202 716.845.5092 www.meengineering.com

M/E PROJECT No: H17018

PROJECT:  
Cherokee Hard Rock Hotel & Casino

DRAWING TITLE:  
PORTE COCHERE LIGHTING CALCULATION SKETCH

SCALE:  
As indicated

DATE:  
03/05/19

DRAWN BY:  
MSC

DRAWING No.:  
**SK-001**

DRAWING REFERENCE No.: