

From: [Dustin Replogle](#)
To: [Dustin Replogle](#)
Subject: RE: Cherokee Smoke Shop
Date: Friday, October 2, 2020 11:13:55 AM

Please see answers below in bold and highlighted to questions that were asked.

Dustin,

Can you help out with a few questions please?

1. Will there be patching at the new gaming area? **Not sure what is referenced. A site visit could be requested by contractor.**
2. What is the existing ceiling height? **+/-8'**
3. There is no ceiling plan, the lighting plan shows a 2x4 ceiling is this accurate? **Light fixtures will be 2x4. Grid is 2x2**
4. Will there be and new HVAC penetrations? **The intent is to utilize existing exterior penetrations. Assume limited patching around new ductwork. As one unit is being completely removed, those penetrations will require patching. Patching will be required where refrigeration lines penetrate exterior walls. This should be coordinated with mechanical contractor for location and quantity.**