

Addendum 1

Questions concerning Bid # 118892- Food Distribution Drive-up windows.

Answers in RED

(1)- Are there existing window openings, if so, what size?

Nowata will be the only one going into an existing window, the window with frame is 3'10" T X 3'11 1/2" W.

(2)- What size of new window that is needed?

The window sizes are in the spec of work

OPTION #1

Ticket window and drawer: 32" wide by 49" tall. 1/4 thick tempered glass

Option #2

Service window to be 30" by 30", self-closing with Aluminum full bottom track

(3)- Are we to cut openings and trim?

Yes, cut openings, frame and trim it out.