

May 11th, 2020

Tony Moraska
Haynes Equipment Company
121 NW 132nd St.
Oklahoma City, Ok 73114

Dear Tony,

RE:Solicitation 2020-001-047- Cherokee Heights New Sewer Station- Mayes County –ID 88682

Per your request by email on May 7th for the above mentioned project please provide response to the following:

Existing Sportsmen Acres Lift Station.

1. Will the new Gorman Pumps have a 7 year warranty?
2. Does the motor stator have Class H insulation?
3. Is the motor warranted for minimum 20 starts per hour?
4. Does the B10 bearing life a minimum of 100,000hours?
5. Is the pump shaft made of 420 stainless steel?
6. The Town of Sportsmen Acres wants the hard-wired phone connection.
7. ABB Mag Meter is acceptable

Cherokee Heights Lift Station.

1. Will the new Gorman Pumps have a 7 year warranty? Need 5H.P. to cover entire pump curve.
2. Does the motor stator have Class H insulation?
3. Is the motor warranted for minimum 20 starts per hour?
4. Does the B10 bearing life a minimum of 100,000hours?
5. Is the pump shaft made of 420 stainless steel?
6. ABB Mag Meter is acceptable.