

September 29, 2020
ADDENDUM NO. 1

CHIMNEY ROCK ROAD
CN-0632/0633-11
MAYES COUNTY

The following are changes and additions to the Plans, Specification and Standards Drawings for this project.

1. Summary Sheets (Sheet 7B of 47) – Fencing Summary – Adjust height of Fence Style CLF from 6’ High to 4’ High, Class A
2. Alignment Data Sheet (Sheet 11 of 47) – Remove SWMP Sheet and replace with Alignment Data Sheet.
3. Plan and Profile (Sheet 27 of 47) – Add note: During the 30 days the road may be closed. See additional notes on Sheet 5.
4. Clarification of question from Pre-Bid Meeting – Will the contractor be responsible for providing the detour signage while the road is closed for bridge construction?

Answer: Yes. Contractor will be responsible for all detour signage during road closure. See Traffic Control and Sequence notes at Proposed Bridge, B-1 on Sheet 5 of 47 of the plans.

A PART OF THIS ADDENDUM NO. 1 IS A REVISED COPY OF SUMMARY SHEET 7B, ALIGNMENT DATA SHEET 11, AND PLAN AND PROFILE SHEET 27 OF THE CHIMNEY ROCK ROAD PLANS AND A COPY OF THE PRE-BID NOTES AND SIGN IN SHEET WHICH WILL BE IN ADDITION TO THE ORIGINAL BID PROPOSAL AND SPECIFICATIONS, AND FURTHER TAKES INTO ACCOUNT THE ABOVE REVISIONS. THIS REVISION WILL NOT AFFECT THE QUANTITIES FOR THIS PROJECT.

ALSO INCLUDED IN THIS PACKET IS A COPY OF THE BID NOTICE FOR INFORMATION PURPOSES ONLY.

FIND ENCLOSED (1) ONE COPY OF EACH OF THE FOLLOWING:

REVISED SUMMARY SHEET 7B
REPLACED ALIGNMENT DATA SHEET 11
REVISED PLAN AND PROFILE SHEET 27
CHIMNEY ROCK ROAD PRE-BID NOTES AND SIGN IN SHEET

BIDDER must acknowledge receipt of this ADDENDUM:

THIS ACKNOWLEDGMENT MUST BE RETURNED AS PART OF THE BID PROPOSAL.