

**Addendum #1 for Questions/Answer for Bid 118984 / 1-25-21**

1. What is the location the air purifiers will be installed?

**They will be installed in the duct work that is already in the Head Start centers.**

2. Is the equipment located in an area where additional ladders/lifts will be required to install?

**No**

3. There are more than one model of air purifier listed in the bid package. Can clarification be given as to how many of each model are being requested in the total quantity of 25 units?

**Only one air purifier model, the AC units are different though.**

\*\*\*\*\*

1. Air cleaning technologies come in many forms, in-ducting being one. Is your organization firm on wanting in-duct units or are you open to consideration of portable units that may be mounted to any surface?

Yes we are firm on wanting in duct.

2. Is area coverage a consideration? For instance, our in-duct units cover 2K, 5K, and 10K sq. ft., and our portable covers 3K.

Yes it is