

Addendum 1

Questions from Vendors about the Freezer/ Cooler Expansion Bid # 119008

Answers in Red.

1. Sub Slab heater on freezer section, is it required? If so base bid or alternate bid?
Slab heater would be an alternate bid; the slab will need to be insulated to code.
2. Permit fees, does the city charge Cherokee Nation fees?
No
3. Do you have an existing plan of the current building because we need to cut the existing slab 9” toward the inside to insure there is insulation and thermal break under door section of cooler/ freezer?
No, we do not have any plans on the building
4. Do you have a contact with the electric company so we can get current loads on building service?
No, will need to contact City
5. Do you want new cooler freezer on the Generator?
Yes it will be on the generator.
6. Do you have a brand of roll around shelves you specify?
METRO MAX I, Antimicrobial
7. The HVAC unit that moves is tied to a fire alarm system, who services your system because the wire drop to the unit will need to be moved and extended?
We will have our alarm company to move the alarm wires.