

December 20, 2022

PROJECT: New Cherokee Nation Hospital
BID PACKAGE 02 – PRECAST CONCRETE AND EARLY SITE UTILITIES
CM CLARIFICATION #08 (POST BID)

Foreman Manhattan Team has added and/or revised the following CM Manual documents for review and inclusion by all contractors within their Scope Package Proposal:

REVISED PROJECT BREAKOUT – Bid Scope 33.02 – Early Site Utilities
Bidders must submit this sheet:

1. Storm Sewer – No Change <ul style="list-style-type: none">This number must match breakout price provided on original bid day (12/15/2022)	\$
2. Water Line – Alternate Material <ul style="list-style-type: none">Due to unforeseen long lead times for the specified 16" Ductile Iron Pipe, provide a new price for the water line system with a revised pipe material of C900 DR18 at all locations where 16" Ductile Iron pipe is currently shown. (Portions or all of Water Line(s) 1, 2, 3, and 5).Include mechanical joint restraints, Megalug, on C900 DR18 Water Lines.All accessories (Bends, Valves, Reducers, Sleeves, Tees, etc.) shall be included in the same locations, types, and quantities as shown – but size shall be adjusted accordingly for the new pipe type.All other water lines in this scope shall remain as designed (SDR21 6", 8", 12" etc. Class 200 PVC).	\$
BASE BID – Including Sales Tax (REVISED)	\$

BID DATE: Thursday, December 22 at 5pm Central

- All bids must be sent in *.pdf format in one single PDF Document to the following email addresses:
To: Shelly McClain shelly-mcclain@cherokee.org
Cc: Michael Flaherty mflaherty@manhattanconstruction.com
- Previously submitted documents are assumed to be a part of this revised bid unless otherwise directed by the bidder (Affidavits, Bonding Letter, TERO Certificate (if applicable), etc.)
- Post Bid Clarification #08 is only being sent to bidders who have already responded to the initial bid opportunity (Previous Bid Date 12/15/2022).

- END OF CM CLARIFICATION -