

HACN HOUSING REHAB SITE DIRECTIONS

Name: Mary Cooksey Buzzard

Telephone: (918)775-5905 or (539)230-4640

Address: PO Box 130
Marble City, OK 74945

County: Sequoyah **Year Built:** 1996

GPS Coordinates: N 35.61485' W094.82290' **Drive Time:** 30 Minutes



Directions: From Cherokee Nation, Go east on Hwy 62 for 1 mile to Hwy 82 turn right go 14.3 miles to Blue Top Rd./Hwy 17 for 10.6 miles turn Right onto Driveway go past 1st Brick House go to end of Driveway, House with White Metal.

Robet Watson
Cost Estimator/Inspector

11/17/21
Date

WorkWrite-Up and Bid Document/By Trade

Mary Buzzard (HVAC)

Contractor Name:

PO Box 130 Marble City, OK 7-4945

(918) 775-5905

Contractor Signature:

This document must be signed to be a valid bid.

PROJECT TYPE: Emergency Repairs Bid Due Date:

Trade	Work Description / Comments	Gen. Spec.	Qty Unit	Item Bid
Electrical				
1 Area: ELECTRICAL				
	HVAC Circuit Wire/220v. Install 220v Circuit Wire/ to supply HVAC.	Div.# 13.D.	3 Ea	
	Install 220 Circuit Wire to Supply Main 3 Ton Split Unit & 2 - 12,000 BTU Mini Split Units.			
HVAC				
2 Area: HVAC				
	Ductwork/Install new ductwork/SF = air conditioned floor area. Install supply and return air ductwork. Seal return air plenums including boxes under(Split Unit) unit and closet ceiling to insure no Attic air is pulled into unit.	Div.# 12	1000 SF	
3 Area: HVAC				
	HVAC Equipment/Central/Cooling & Gas Heating 3.5 TON/14 SEER, New.Install new HVAC cooling Equipment (14 SEER). INSIDE AND OUTSIDE EQUIPMENT/INCLUDING AIR HANDLER,COPPER LINES,CONDENSOR COILS, EVAP. COILS. Thermostat AND COMPRESSOR.	Div.# 12	1 Ea	
	Unit is to supply a 2,000sf Home.			
4 Area: LIVING ROOM #1				
	HVAC Equipment/Mini Split/Ductless system. 12 K BTU Heating & Cooling.	Div.# 12	2 Ea	

Trade	Work Description / Comments	Gen. Spec.	Qty Unit	Item Bid
-------	-----------------------------	------------	----------	----------

All construction shall be in accordance with local codes, manufacturers' recommended installation procedures, good quality workmanship practices, General Specifications and Lead-Based Paint requirements when applicable. Conflicts between requirements will be resolved by compliance with the more stringent requirement.

Total: