

# WorkWrite-Up and Bid Document/By Trade

**Sherri Henry**

771 North 4429 Salina, OK 7-4365  
 (918) 864-2869

*Contractor Name:*

*Contractor Signature:*

*This document must be signed to be a valid bid.*

**PROJECT TYPE: Emergency Repairs      Bid Due Date:**

Trade	Work Description / Comments	Gen. Spec.	Qty Unit	Item Bid
<b>HVAC</b>				
<b>1 Area: HVAC</b>	Ductwork/Install new ductwork/SF = air conditioned floor area. Install supply and return air ductwork. Seal return air plenums including boxes under(Split Unit) unit and closet ceiling to insure no Attic air is pulled into unit.	Div.# 12	1200 SF	
<b>2 Area: HVAC</b>	HVAC Equipment Replacement/Central Heating & Cooling 2 1/2 ton / Propane Gas Furnace/ 2 1/2TON System. INCLUDES: Coil Box, Condensate Line, Ceiling Registers, Thermostat, Filter Grill, Condenser.	Div.# 12	1 Ea	

**All construction shall be in accordance with local codes, manufacturers' recommended installation procedures, good quality workmanship practices, General Specifications and Lead-Based Paint requirements when applicable. Conflicts between requirements will be resolved by compliance with the more stringent requirement.**

**Total:**

