

From: [Rebecca Scheufler](#)
To: rlasarsky@buildingfirstnations.com; jpinkston@buildingfirstnations.com; nathangregory@stoutconstruction.net; chenrie@maskabuilders.com; jpeck@buiok.com; stephen@ascendok.com; lharper@siglerheatandair.com; estimating@2JsElectric.com; keving@aapiok.com; info@buiok.com; bb@brheavy.com; nlimore@arrowhead-usa.com; godwin.l@mcintosh.com; cfisher@bronzеоakgc.com; jonhumphrey@stoutconstruction.com; smorgan@southstonellc.com; rickm@aapiok.com; mikeros99@hotmail.com; chadbell77@hotmail.com; terry@limestoneconstruction.com; m.haught@candorbuild.com; dustin@atmosdesignbuild.com; sam@limestoneconstruction.com; tony@limestoneconstruction.com; williamg@lhctulsa.com; noahb@colburnelect.com; NathanGregory@stoutconstruction.net
Cc: [Rebecca Scheufler](#)
Subject: Additional Questions and Answers
Date: Thursday, March 9, 2023 9:50:00 AM
Attachments: [CNFO Campus Improvements - Pre-con RFI \(03.10.23\).pdf](#)
[image002.png](#)

Please see attached.

Also,

On Addendum #2 there is a new gas line shown running back to the new RTU. Can you please clarify the size of this line?

2".

[Rebecca Scheufler](#)

Buyer



918.384.5856 o

918.829.4146 m

Rebecca.scheufler@cnent.com